

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3550-0026:232 Page 1 of 1

**CATEGORY:** Door Closer/Holders/Releasing Devices

**LISTEE:** Simplex, 100 Simplex Drive, Westminster, MA 01441-0001  
Contact: Paul Mattern (978) 731-8542 \*FAX (978) 731-8881

**DESIGN:** Models 2088-9608, 2088-9608C, 2088-9609, 2088-9609C, 2088-9607, 2088-9607C, 2088-9610 and 2088-9611 door holders. These door holders consist of electromagnetic assemblies housed in either listed outlet boxes or secured within aluminum or zinc cover plates. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 12 VAC, 24 VAC, 120 VAC, 240 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The units are intended to be flush, recessed or surface mounted to the adjacent wall surface.

**MARKING:** Listee's name, model number, electrical rating, load rating, and UL label.

**APPROVAL:** Listed as door holders for use on swinging type fire doors where permitted per codes. For indoor use only.

**XLf:** 3550-1459:112

\*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**